

CITY OF CHISHOLM 2011 DRINKING WATER REPORT

The City of Chisholm is issuing the results of monitoring done on its drinking water for the period of January 1 to December 31, 2011. The purpose of this report is to advance consumers' understanding of drinking water and heighten awareness of the need to protect precious water resources.

SOURCE OF WATER

The City of Chisholm provides drinking water to its residents from surface water source: surface water drawn from the Fraser-Humphrey Pit.

The water provided to customers may meet drinking water standards, but the Minnesota Department of Health has also made a determination as to how vulnerable the source of water may be to future contamination incidents. If you wish to obtain the entire source water assessment regarding your drinking water, please call 1-800-818-9318 (and press 5) during normal business hours. Also, you can view it on line at: www.health.state.mn.us/divs/eh/water/swp/swa.

Call the Public Utilities Office at 254-7905 if you have any questions about your drinking water or would like information about opportunities for public participation in decisions that may affect the quality of the water.

COMPLIANCE WITH NATIONAL PRIMARY DRINKING WATER REGULATIONS

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum productions, and can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive Contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (EPA) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the *Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791*.

RESULTS OF MONITORING

No contaminants were detected at levels that violated federal drinking water standards. However, some contaminants were detected in trace amounts that were below legal limits. The table that follows shows the contaminants that were detected in trace amounts last year. (Some contaminants are sampled less frequently than once a year; as a result, not all contaminants were sampled for in 2011. If any of these contaminants were detected the last time they were sampled for, they are included in the table along with the date that the detection occurred.)

Key to abbreviations to Test Result Tables:

MCLG – Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL – Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

AL – Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MRDL – Maximum Residual Disinfectant Level

MRDLG – Maximum Residual Disinfectant Level Goal

90th Percentile Level (90th % Level): This is the value obtained after disregarding 10 percent of the samples taken that had the highest levels. (For example, in a situation in which 10 samples were taken, the 90th percentile level is determined by disregarding the highest result, which represents 10 percent of the samples.)

ppb – Parts per Billion: Which can also be expressed as micrograms per liter (mg/l).

ppm – Parts per Million: Which can also be expressed as milligrams per liter (mg/l)

NA – Not Applicable: Does not apply.

TEST RESULTS

Contaminant (units)	MCLG	AL	90% Level	# of Site over AL	Typical Source of Contaminant
Copper (ppm) (6/17/2010)	1.3	1.3	.05	0 out of 20	Corrosion of household plumbing systems; Erosion of natural deposits.
Lead (ppb) (6/17/2010)	0	15	4.1	0 out of 20	Corrosion of household plumbing systems; Erosion of natural deposits.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Chisholm is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

TEST RESULTS

Contaminant (units)	MCLG	MCL	Level Found		Typical Source of Contaminant
			Range (2010)	Average /Result*	
Fluoride (ppm)	4	4	.8 - .93	.92	State of Minnesota requires all municipal water systems to add fluoride to the drinking water to promote strong teeth; Erosion of natural deposits; Discharge from fertilizer & aluminum factories.
Haloacetic Acids (HAA5) (ppb)	0	60	N/A	8	By-product of drinking water disinfection.
TTHM (Total trihalomethanes) (ppb)	0	80	N/A	18.1	By-product of drinking water disinfection.

*Average/Result This is the value used to determine compliance with federal standards. It sometimes is the highest value detected and sometimes is an average of all the detected values. If it is an average, it may contain sampling results from the results of the previous year.

Contaminant (units)	MCLG	MCL	**	***	Typical Source of Contaminant
Turbidity (NTU)	N/A	TT	100	<1.0	Soil Runoff.

Lowest Quarterly Percentage of Samples Meeting the Turbidity Limits. *Highest Single Measurement. Turbidity is a measure of the clarity of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system.

Contaminant (units)	MRDLG	MRDL	****	*****	Typical Source of Contaminant
Chlorine (ppm)	4	4	.2 - .5	.31	Water additive used to control microbes.

****Highest and Lowest Monthly Average *****Highest Quarterly Average

Contaminant	Unit	% Removal Required	% Removal Achieved	# of Quarters out of Compliance	Typical Source of Contaminant
Total Organic Carbon	0.0% Removed	N/A	N/A->0%	0	Naturally present in the environment

Some contaminants do not have Maximum Contaminant Levels established for them. These unregulated contaminants are assessed using state standards known as health risk limits to determine if they pose a threat to human health. If unacceptable levels of an unregulated contaminant are found, the response is the same as if an MCL has been exceeded; the water systems must inform its customers and take other corrective actions. In the table that follows are the unregulated contaminants that were detected

Contaminant (units)	MCLG	Level Found		Typical Source of Contaminant
		Range (2011)	Average /Result	
Sodium (ppm) (5/25/2010)		N/A	7.0	Erosion of natural deposits.
Sulfate (ppm) (5/25/2010)		N/A	33.5	Erosion of natural deposits.

IMPORTANT NOTICE: Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.