



NOTE 1: Regardless of its size, any ASME tank filled on-site must be located so that the filling connection and fixed liquid level gauge are at least 10 ft from any external source of ignition (i.e. open flame, window A/C, compressor, etc). Intake to direct vented gas appliance or intake to a mechanical ventilation system.

(For SI Units: 1 ft = 0.3048 m)

Figure I-2 Aboveground ASME Containers.

(This figure for illustrative purposes only; text shall govern.)